

# Case study factsheet Ringkøbing, DENMARK



## Ringkøbing District heating

### Lean-burn gas engine

Main CHP project indicators		
Heat capacity (total)	kW <sub>th</sub>	9,680
Electrical capacity (total)	kW <sub>el</sub>	7,861
Technology	Motor engine	
No. of units	1	
Manufacturer	Wärtsilä	
Type of Fuel	lean-burn gas	
Heat: yearly generation	MWh	
Electricity: yearly generation	MWh	
Year of construction	2002	
Total investment costs	EUR	4.2 M €
Financing	no specification	
State support	no specification	
Return of investment (payback period)	Years	no specification
Location	Ringkøbing, Denmark	
Information	bent.iversen@wartsila.com	

#### General description of the case



local utility company RAH.

The Wärtsilä 20V-34SG generating set is situated in the Rindum plant, a substation in Ringkøbing Fjernvarmeværk's district heating network. The sparkignited engine uses lean gas and delivers heat to the town's 3,500 consumers and electricity to the

#### Success factors


The engine produces significantly more electrical power compared to the gas turbine it replaced. The electrical efficiency of the gas turbine was 27 % while the efficiency of this 20-cylinder gas engine is almost 44%. The operator: was faced with tough environmental demands from the authorities to reduce the NOX emissions from the gas turbine, in addition to which a major overhaul was scheduled for the gas turbine. The high total efficiency of the plant gives the owner maximum security in an open market where fuel and power prices are volatile.

#### **Main barriers**

No specific barriers has been identified.

#### Comparison: before and after

The cost of heat production from the Rindum plant has been reduced by 20 % compared with continuing operation of the gas turbine.



#### **Conclusions**

Replacement of an old plant with a new modern plant with the same heat production can increase the power yield considerably.